

WELL COMPLETION REPORT
3/71

LAKE CAROL

41 27 57 73 43 02

PUTNAM COUNTY DEPARTMENT OF HEALTH
Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1061

OWNER	NAME <u>DOUGLAS J. ELLI</u>		ADDRESS <u>LAUREL LANE</u>		19 (Lot Number)	
LOCATION OF WELL	<u>LAUREL LANE</u> (No. & Street)		<u>MENT</u> (Town)			
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM	<input type="checkbox"/> TEST WELL	705 L	
	<input type="checkbox"/> PUBLIC SUPPLY	<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING	<input type="checkbox"/> OTHER (Specify)		
DRILLING EQUIPMENT	<input checked="" type="checkbox"/> ROTARY	<input type="checkbox"/> COMPRESSED AIR PERCUSSION	<input type="checkbox"/> CABLE PERCUSSION	<input type="checkbox"/> OTHER (Specify)		
	CASING DETAILS	LENGTH (feet) 25	DIAMETER (inches) 6	WEIGHT PER FOOT 17	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED	DRIVE SHOE <input type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED	<input type="checkbox"/> PUMPED	<input type="checkbox"/> COMPRESSED AIR	HOURS	G.P.M. 7	YIELD (G.P.M.)
WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet)		DURING YIELD TEST (feet)		Depth of Completed Well in feet below Land surface:	
SCREEN DETAILS	MAKE				LENGTH OPEN TO AQUIFER (feet)	
	SLOT SIZE 110 X 433	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches)	FROM (feet) TO (feet)

DEPTH FROM LAND SURFACE FEET TO FEET		FORMATION DESCRIPTION	Sketch exact location of well with distances, to at least two permanent landmarks.
0	5		
5	210	granite	
If yield was tested at different depths during drilling, list below			
FEET		GALLONS PER MINUTE	

DATE WELL COMPLETED 10-15-71	DATE OF REPORT 4-25-72	WELL DRILLER (Signature) <i>John J. Bell</i>
---------------------------------	---------------------------	---